

PENETRATION & LINEAR GAP SEALS SCHEME

Certificate number: IFCC 1728

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd, part of the Kiwa UK Group

This is to certify that

ARC Building Solutions Ltd

Unit J Gildersome Spur

Leeds

West Yorkshire

LS27 7JZ

Telephone: 0113 252 9428

Who manufactures the following systems:

ARC Party Wall DPC & T-Barrier

have satisfied the requirements of the SDP-14 Penetration and Linear Gap Seals scheme v1.5. This includes the testing of products to, or generally in accordance with, **BS EN 1366-4:2006+A1:2010 or BS EN 1366-4:2021**, the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application are detailed on page 2 of this certificate.

Initial Certification: 27 July 2022

Revised: 03 February 2025

Valid to: 26 July 2027

Issue number: 2


David Mowatt

Head of IFC Certification /

Kiwa Group Limited

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*



**ARC Party Wall Cavity Stop Sock & Party Wall DPC**

Cavity Size (mm)	Substrate Type	Rating E/I (mins)	Compression Fit (mm)	Thickness (mm)	Orientation	Test (Specimen)
0-300	M	240/120	None	250	H	WF 513959 (A)
0-300	M	240/120	None	250	V	WF 358532 (E)

ARC Party Wall TCB

Cavity Size (mm)	Substrate Type	Rating E/I (mins)	Compression Fit (mm)	Thickness (mm)	Orientation	Test (Specimen)
0-150	01/M	60/60	5	250	V H	WF 438534B (D) WF 517911 (B)

ARC T-Barrier (Masonry)

Cavity Size (mm)	Substrate Type	Rating E/I (mins)	Compression Fit (mm)	Thickness (mm)	Orientation	Test (Specimen)
0-300	M	240/120	None	250	H	WF 513959 (A)
0-300	M	240/120	None	250	V	WF 358532 (E)

ARC T-Barrier (Timber Frame)

Cavity Size (mm)	Substrate Type	Rating E/I (mins)	Compression Fit (mm)	Thickness (mm)	Orientation	Test (Specimen)
0-150	01/M	60/60	5	250	V	WF 438534B (D)

M = Masonry, H = Horizontal, V = Vertical, 01/M = OSB 1 side &/or masonry, 02/M = OSB 2 side &/or masonry

Signed on behalf of Kiwa UK



David Mowatt
Head of IFC Certification /
Kiwa Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.