

PENETRATION & LINEAR GAP SEALS SCHEME SDP13

Certificate number: IFCC 1729

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

ARC Building Solutions Ltd

Unit J Gildersome Spur

Leeds

West Yorkshire

LS27 7JZ

Telephone no. : 0113 252 9428

Who manufactures the following systems:

ARC Eco-Closer & Eco-Closer Plus

have satisfied the requirements of the above scheme. This includes the testing of products to EN1366-4 the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and reports are detailed on page 2 of this certificate.

First Issued: 27 July 2022


Revised: 21 December 2023

Valid to: 26 July 2027

Issue status: 3

Ian Woodhouse
Head of Technical – IFC Certification
Kiwa Ltd

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*

**ARC Eco-Closer**

Cavity Size (mm)	Substrate Type	Rating E/I (mins)	Compression Fit (mm)	Orientation	Test (Specimen)
0-150	M	60/15	None	H	WF 434661 (B)
0-150	M	60/15	None	Vfs	WF 502321A (E)
0-150	M	60/15	None	Vnfs	WF 431284A (E)

ARC Eco-Closer Plus

Cavity Size (mm)	Substrate Type	Rating E/I (mins)	Compression Fit (mm)	Orientation	Test (Specimen)
150-300	M	120/15	3	H	WF 396248 (A)
150-300	M	120/15	3	Vnfs	WF 520474 (A)
150-300	M	120/15	3	Vfs	WF 520474 (B)

M = Masonry, H = Horizontal, Vfs = Vertical Fire Side, Vnfs = Vertical Non-Fire Side

Signed on behalf of Kiwa Ltd

Ian Woodhouse
Head of Technical – IFC Certification