

PENETRATION & LINEAR GAP SEALS SCHEME SDP13

Certificate number: IFCC 1841

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

ARC Building Solutions Ltd

Unit J Gildersome Spur

Leeds

West Yorkshire

LS27 7JZ

Telephone no. : 0113 252 9428

Who manufactures the following systems:

ARC TCB Square

have satisfied the requirements of the above scheme. This includes the testing of products to EN1366-4 the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification is detailed in the Engineering Assessment Report PAR/23886/01 and in the test reports on page 2 of this certificate.

First Issued: 01 June 2023

Valid to: 31 May 2028


Issue Number: 1

Ian Woodhouse

Head of Technical – IFC Certification

Kiwa Ltd

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*



ARC TCB Square

Cavity Width (mm)	Substrate Type	Rating E/I (mins)	Compression Fit (mm)	Orientation	Test (Specimen)
0-50	M/OSB/CP	90/15	15	H/V	WF 361952 (F)
51-75	M/OSB/CP	60/15	15	H/V	WF 434661/R (C)
76-150	M/OSB/CP	60/60	15	H/V	IF 11034 (B)

M = Masonry, OSB = Orientated Strand Board, CP = Cement Particle Board H = Horizontal, V = Vertical

Signed on behalf of Kiwa Ltd

Ian Woodhouse
Head of Technical – IFC Certification

CERTIFICATE

