Certificate

Penetration & Linear Gap Seals Scheme

Certificate Number: IFCC 1732

Initial Certification:	27 July 2022	**Revised:**	11 September 2026
Valid to:	26 July 2027	**Issue No:**	5

Issued by **IFC Certification Ltd** part of the Kiwa UK Group

This is to certify that

ARC Building Solutions Ltd

Unit J Gildersome Spur
Leeds
West Yorkshire
LS27 7JZ
Telephone: 0113 252 9428

Who manufactures the following systems:

ARC Fire Stop Strip

has satisfied the requirements of the SDP-14 Penetration and Linear Gap Seals scheme v1.6. This includes the testing of products to, **BS EN 1366-4:2006+A1:2010 or BS EN 1366-4:2021,** the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application are detailed on page 2 of this certificate.

David Mowatt
Head of IFC Certification /
Kiwa UK

kiwa CERTIFIED Product Scheme IFC Certification

UKAS PRODUCT CERTIFICATION 0175

Certificate is only valid if verified on the website.
Check the validity of this certificate by scanning this QR Code or visiting www.ifccertification.com/search/

KIWA
IFC Certification Ltd
Ground Floor, Suite A
Building 2,
Bear Brook Office Park
Walton Street, Aylesbury,
Bucks, HP21 7GQ

Certificate

Certificate Number: IFCC 1732 issue 5

ARC Fire Stop Strip

Cavity Size (mm)	Substrate Type	Rating E/I (mins)	Compression Fit (mm)	Thickness (mm)	Orientation	Test (Specimen)
50 (maximum)	Masonry	240/180	None	100 (minimum)	Horizontal Vertical	WF 431274 (E) WF 513886 (D)
50	Masonry / OSB	120/120	None	100	Vertical	WF 555480A/R (E)

Signed on behalf of Kiwa UK



David Mowatt
Head of IFC Certification /
Kiwa UK

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.