

Certificate

Linear Gap Seals Scheme Certificate Number: IFCC 1959

kiwa

Initial Certification: 20 January 2025
Valid to: 26 July 2029

Revised: 11 September 2026
Issue No: 3

Issued by **IFC Certification Ltd** part of the Kiwa UK Group

This is to certify that

ARC Building Solutions Ltd

**Unit J Gildersome Spur
Leeds
West Yorkshire
LS27 7JZ
Telephone: 0113 252 9428**

Who manufactures the following systems:

ARC Soffit Slab

has satisfied the requirements of the SDP 14 Linear Gap Seals scheme v1.6. This includes the testing of products to **BS EN1366-4:2006+A1:2010**, the inspection of their Factory Production Control, and continuing surveillance audits, and testing of samples of products taken from production. The product specification and reports to achieve **up to 90 minutes integrity and 15 minutes insulation** are detailed on page 2 of this certificate.



David Mowatt
Head of IFC Certification /
Kiwa UK

This certificate consists of 2 pages. Publication of this certificate is permitted



Certificate is only valid if verified on the website.
Check the validity of this certificate by scanning this
QR Code or visiting www.ifccertification.com/search/

KIWA
IFC Certification Ltd
Ground Floor, Suite A
Building 2,
Bear Brook Office Park
Walton Street, Aylesbury,
Bucks, HP21 7GQ

ARC Soffit Slab

Test Report -Specimen	Aperture Size (mm)	Substrate Type	Integrity (mins)	Insulation (mins)	Compression (mm)	Thickness (mm)
502323A/R Specimen A	400 x 600	Masonry	90	15	5	150
557086A/R* Specimen A	600 x 600	Masonry	210	60	0	100

*NB. Test conducted generally in accordance with the standard; the test result is only valid to the specimen as tested.

Signed on behalf of Kiwa UK



David Mowatt
Head of IFC Certification /
Kiwa UK

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.